

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Switch
Name and address of the applicant	Končar Niskonaponske Sklopke I Prekidaci d.o.o. Borongajska cesta 81b 10001 Zagreb Croatia
Name and address of the manufacturer	Končar Niskonaponske Sklopke I Prekidaci d.o.o. Borongajska cesta 81b 10001 Zagreb Croatia
Name and address of the factory	<input type="checkbox"/> Additional information on page 2
Note: When more than one factory, please report on page 2	Končar Niskonaponske Sklopke I Prekidaci d.o.o. Borongajska cesta 81b 10001 Zagreb Croatia
Ratings and principal characteristics	Ui=690 Vac, Ith=16 A, Icw=250 A - 1 sec., Icm=1100 A peak 2 single pole contacts, 2 decks  AC-21A: 690 V, 16 A  AC-3: 230 V, 15 A - 4 kW 400 V, 12 A - 5,5 kW 690 V, 7 A - 5,5 kW
Trademark (if any)	KONČAR
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	GX16
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2008, IEC 60947-3:2008/AMD1:2012, IEC 60947-3:2008/AMD2:2015
As shown in the Test Report Ref. No. which forms part of this Certificate	2215774.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Switch
Name and address of the applicant	Končar Niskonaponske Sklopke I Prekidaci d.o.o. Borongajska cesta 81b 10001 Zagreb Croatia
Name and address of the manufacturer	Končar Niskonaponske Sklopke I Prekidaci d.o.o. Borongajska cesta 81b 10001 Zagreb Croatia
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Končar Niskonaponske Sklopke I Prekidaci d.o.o. Borongajska cesta 81b 10001 Zagreb Croatia
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Ui=690 Vac, Ith=20 A, Icw=250 A - 1 sec., Icm=1100 A peak 2 single pole contacts, 2 decks  AC-21A: 690 V, 20 A  AC-3: 230 V, 15 A - 4 kW 400 V, 12 A - 5,5 kW 690 V, 7 A - 5,5 kW
Trademark (if any)	KONČAR
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	GX20
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2008, IEC 60947-3:2008/AMD1:2012, IEC 60947-3:2008/AMD2:2015
As shown in the Test Report Ref. No. which forms part of this Certificate	2215774.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Switch
Name and address of the applicant	Končar Niskonaponske Sklopke I Prekidaci d.o.o. Borongajska cesta 81b 10001 Zagreb Croatia
Name and address of the manufacturer	Končar Niskonaponske Sklopke I Prekidaci d.o.o. Borongajska cesta 81b 10001 Zagreb Croatia
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Končar Niskonaponske Sklopke I Prekidaci d.o.o. Borongajska cesta 81b 10001 Zagreb Croatia
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Ui=690 Vac, Ith=32 A, Icw=650 A - 1 sec., Icm=1100 A peak 2 single pole contacts, 2 decks  AC-21A: 690 V, 32 A  AC-23A: 230 V, 30 A - 7,5 kW 400 V, 30 A - 15 kW 690 V, 17,5 A - 15 kW
Trademark (if any)	KONČAR
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	GX32
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2008, IEC 60947-3:2008/AMD1:2012, IEC 60947-3:2008/AMD2:2015
As shown in the Test Report Ref. No. which forms part of this Certificate	2215774.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switch
Name and address of the applicant	Končar Niskonaponske Sklopke I Prekidaci d.o.o. Borongajska cesta 81b 10001 Zagreb Croatia
Name and address of the manufacturer	Končar Niskonaponske Sklopke I Prekidaci d.o.o. Borongajska cesta 81b 10001 Zagreb Croatia
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Končar Niskonaponske Sklopke I Prekidaci d.o.o. Borongajska cesta 81b 10001 Zagreb Croatia
Note: <i>When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	<p><math>U_i=690</math> Vac, <math>I_{th}=40</math> A, <math>I_{cw}=650</math> A - 1 sec., <math>I_{cm}=1100</math> A peak 2 single pole contacts, 2 decks</p> <p>AC-21A: 690 V, 40 A</p> <p>AC-23A: 230 V, 34 A - 7,5 kW 400 V, 35 A - 18,5 kW 690 V, 17,5 A - 15 kW</p>
Trademark (if any)	KONČAR
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	GX40
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2008, IEC 60947-3:2008/AMD1:2012, IEC 60947-3:2008/AMD2:2015
As shown in the Test Report Ref. No. which forms part of this Certificate	2215774.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands


