

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switch-disconnectors
Name and address of the applicant	Koncar Niskonaponske Sklopke I Prekidaci d.o.o. Borongajska B.B. 81b, 10001 Zagreb Croatia
Name and address of the manufacturer	Koncar Niskonaponske Sklopke I Prekidaci d.o.o. Borongajska B.B. 81b, 10001 Zagreb Croatia
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Koncar Niskonaponske Sklopke I Prekidaci d.o.o. Borongajska cesta 81b 10001 Zagreb Croatia
Note: <i>When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	DC-21B 1000 Vdc
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	PV25, PV32, PV40
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2007, IEC 60947-1:2007/AMD1:2010, IEC 60947-1:2007/AMD2:2014, IEC 60947-3:2008, IEC 60947-3:2008/AMD1:2012, IEC 60947-3:2008/AMD2:2015
As shown in the Test Report Ref. No. which forms part of this Certificate	2176068.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

